Letter of Attestation

Document:	**70065012-4**	**Master Contract:**	**264073**
Project:	**70065012**	**Date Issued:**	**2016-09-01**
Issued to:	**Preformed Line Products**		

CSA Group, Certification and Testing hereby confirms that it has completed an evaluation of:

PV Module Rack Mounting System, Power Rail™ P6/P8/P14 with coated hardware

CSA Group, Certification and Testing hereby attests that the products identified above and described in CSA test report 70065012 dated April 14, 2016 and CFV Solar Test Report 15087 dated April 19, 2016 complies with the following standards/tests for mounting and rack systems, to the extent applicable:

UL 2703 (01/28/2015) Sections: 13, 17, 18 & 22 -	Mounting Systems, Mounting Devices, Clamping / Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels

Stress:	Pre-stress characterization (§13):	Stress Test Requirement:	Post-stress characterization (§13):
§17 Thermal Cycling (90°C / -40°) 200 cycles:	Pass	Pass	Pass
§18 Humidity Cycling (85°C @ 85% RH / -40°) 10 cycles:	Pass	Pass	Pass
§22a 135% Rating (40.5 A / 1 hour):	Pass	Pass	Pass
§22a 200% Rating (60 A / 2 min):	Pass	Pass	Pass
§22b 240 VAC @ 5,000 A:	Pass	Pass	Pass

Issued by: _____

Steve Dudden
Certification Manager

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS.
QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME OF THE CANADIAN STANDARDS ASSOCIATION AND CSA GROUP OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF THE CANADIAN STANDARDS ASSOCIATION OPERATING AS CSA GROUP, CERTIFICATION AND TESTING DIVISION.